



# Puget Sound Clean Air Agency

Notice of  
Construction No.

12564

PUGET SOUND  
Clean Air Agency

1904 3rd Ave, Ste 105  
Seattle, WA 98101-3317

Registration No. 21147

Telephone: (206) 343-8800  
Fascimile: (206) 343-7522

## DETERMINATION OF NONSIGNIFICANCE

### Description of Proposal

**Two Cleaver Brooks D-Type Industrial Water-Tube boilers each with 30,000 pounds per hour capacity at an approximately 36.5 MMBtu/hr heat input and two Cleaver Brooks D-Type Industrial Water-Tube boilers each with 80,000 pounds per hour capacity at an approximately 96.9 MMBtu/hr heat input. The steam boilers will normally fire on natural gas with ultra-low sulfur diesel back-up. All boilers are equipped with flue gas recirculation, oxygen trim and low-NOx burners. The boilers will be located in Building 3-150.**

### Proponent

**Boeing Commercial Airplane Seattle  
PO Box 3707, MC 6X2-06  
Seattle, WA 98124**

### Location of proposal, including street address if any

**Boeing Commercial Airplane Seattle, 7700 E Marginal Wy S, Seattle, WA 98108**

### Lead Agency

**Puget Sound Clean Air Agency**

The lead agency for this proposal has determined that it does not have a probable significant adverse impact on the environment. An environmental impact statement (EIA) is not required under RCW 43.21C.030(2)(c). This decision was made after review of a completed environmental checklist and other information on file with the lead agency. This information is available to the public on request.

There is no comment period for this DNS.

This DNS is issued under WAC 197-11-340(2); the lead agency will not act on this proposal before Jan, 30, 2026.  
 Comments must be submitted by that date.

We have identified and adopted this document as being appropriate for this proposal after independent review. The document meets our environmental review needs for the current proposal and will accompany the proposal to the decision-maker.

Name of agency adopting document: **Puget Sound Clean Air Agency**

Contact person, if other than responsible official: **Maggie Corbin** Phone: **(206) 689-4087**

Responsible Official: **John Dawson**  
Position/Title: **Engineering Manager**  
Address: **1904 3rd Ave, Ste 105, Seattle, WA 98101-3317**

Date Dec 18, 2025

Signature

A handwritten signature in blue ink that reads 'John Dawson'.